



## Compact Single Compressor Heat Pumps

### Features and Benefits

- Available up to 12kW
- Single and three phase models
- Low running costs
- Low carbon emissions
- Ease of installation
- Complete kit available
- Access to industry grants
- UK manufactured



### Product Description

The Kensa [single compressor range](#) of Compact heat pumps are designed to provide space heating and domestic hot water production (optional extra) for well insulated buildings.

Available in [single](#) phase models.

Kensa heat pumps use low grade renewable energy from the ground and concentrates this to a higher temperature to provide heat into a buildings heating system.

Heat pumps are ideally suited to [underfloor heating](#) distribution systems mounted in screed as the large heat emitting surface area means a low flow temperature from the heat pump can be used increasing its efficiency.

Radiators can also be used within the heating distribution system however due to the higher flow temperatures required from the heat pump, its efficiency will be decreased and hence it is important to assess the viability of installing a unit against the alternative fuels available.

As a UK manufacturer, Kensa offers a high quality product which is supported by industry leading technical support to ensure the application engineering is performed to the highest standard.



## Compact Single Compressor Heat Pumps

	Single Phase			
Nominal thermal kW rating	6	8	10	12
Part No	C060-S1H	C080-S1H	C100-S1H	C120-S1H
MCS Approved	BBA00 55/02	BBA00 55/03	BBA00 55/04	BBA00 55/05
<b>Performance data—rated heating output at B0/W35 BS EN14511</b>				
Power consumption	2.1	2.6	2.9	3.6
Coefficient of performance*	4.13	4.14	4.16	4.13
Immersion heater output	Kensa heat pumps do not feature back-up electric immersion heaters**			
<b>Brine (primary) based on 0°C in, -4°C out</b>				
Design flow rate kg/min	19.2	26.4	30.6	37.7
Pressure drop kPa at design flow rate	11.6	11.7	15.3	22.2
Max inlet temperature °C	15			
Min temperature °C (Outlet)	-5 (at standard settings)			
<b>Heating water (secondary) based on 30°C in, 35°C out</b>				
Design flow rate l/min	18.6	25.3	29.1	36.0
Pressure drop kPa at design flow rate	8.05	9.3	12.3	18.7
Max flow temperature °C***	55			
<b>Electrical Values @B0/W35</b>				
Rated Voltage	220 – 240 V / 50-60 Hz			
Power supply rating amps	25	25	32	32
Rated current (max) amps	18.4	21.8	26.2	32.7
Typical running current @ B0/W35 amps	10.4	13.6	13.9	17.7
Starting current amps****	30	30	30	40



## Compact Single Compressor Heat Pumps

	Single Phase			
Nominal thermal kW rating	6	8	10	12
<b>Refrigerant circuit</b>				
Process medium	R407C			
Fill volume kg	1.3	1.0	1.3	1.3
Compressor type	Scroll			
<b>Dimensions</b>				
H x W x L (mm)	900 x 550 x 570			
Dry weight kg	92	95	100	110
<b>Operating pressure</b>				
Brine circuit min(primary) bar g	0.3			
Heating water circuit min (secondary) bar g	0.3			
Low pressure reset bar g	1.8			
<b>Connection sizes</b>				
Primary IN and OUT (speedfit) mm	28			
Heating flow and return (speedfit) mm	28			

\* The COP figure quoted is calculated as per EN14511

\*\* In-built immersion heaters will increase running costs and CO<sub>2</sub> emissions as they use direct electricity, because of this Kensa heat pumps do not include them.

\*\*\* By increasing the flow temperature from the heat pump the efficiency of the unit will drop and the COP decreases.

\*\*\*\* Kensa single phase Compact heat pumps incorporate smart starts as standard to limit the starting current of the compressors. For full details on how the starting currents are calculated please contact Kensa.

Note: Design flowrates are for a ground temperature of 0 and -4°C and a load temperature of 30°C and 35°C



## Compact Single Compressor Heat Pumps

### Sizing

**SPACE HEATING:** Assumes 40 watts per square metre peak heating requirement. Precise sizing can be established by referring to the SAP report. In every instance reviewed in 2007/8, heat losses are between 30 - 40 watts per square metre for properties built to Part L 2006 (England and Wales). As a result, it may be possible to offer a smaller, less expensive heat pump and accessories. In every instance, Kensa heat pumps are sized to handle the peak heating load; Kensa appliances do not feature integral immersion heaters.

**DOMESTIC HOT WATER - SLINKY REQUIREMENT:** Sizing a heat pump and its ground arrays for domestic hot water is more complex. Whereas occupancy levels and lifestyle habits will not greatly affect the space heating load, they will impact on domestic hot water requirements. Clearly, an additional burden is imposed on the ground arrays; in addition, the year round requirement for domestic hot water means there is a lesser opportunity for the ground to recover temperature. As a consequence, extra pipework must be buried. The Slinky requirement outlined in the table below reflects typical water usage; please contact Kensa if requirements are considered exceptional.

**DOMESTIC HOT WATER - METHOD OF OPERATION:** The heat pump can be in space heating OR domestic hot water mode. When in DHW mode, the heat pump will achieve the highest possible stored water temperature which means its performance will be enhanced in the summer months (when ground conditions are warmest). After completing its DHW duty, the heat pump will return to space heating mode, if required. The heat pump will not be able to return to DHW model for two hours. For this reason, a suitably -sized storage cylinder should be specified. Any cylinder should be equipped with integral immersion heaters to provide a boost, if required. These immersion heaters should be run during the low cost periods provided with an Economy Ten tariff. Contact Kensa for further information. Kensa supplies a special three way valve to divert between modes. The installer would need to provide a time clock to control DHW periods.

Nominal thermal kW rating	6	8	10	12
<b>Building size</b>				
Building size m <sup>2</sup>	150	200	250	300
<b>Space heating</b>				
Slinkies	2 x 30m	2 x 40m	2 x 50m	3 x 40m
Manifold	2 way	2 way	2 way	3 way
Antifreeze* litres	50	75	100	125
<b>Space heating and domestic hot water production</b>				
Slinkies	2 x 40m	2 x 50m	3 x 40m	3 x 50m
Manifold	2 way	2 way	3 way	3 way
Antifreeze* litres	75	100	125	125
Recommended minimum heat transfer area in DHW tank (not supplied)	1.2m <sup>2</sup>	1.6m <sup>2</sup>	2.0m <sup>2</sup>	2.4m <sup>2</sup>

\* Antifreeze quantities quoted are a minimum and may need to be increased depending on the distance between the heat pump and ground array manifold. The concentration should be a minimum of 20% and offer a protection to -10 °C.

**Please note the above methodology is not compliant with MCS which requires a full heat loss calculation to be carried out.** The values in the table are a guide only and Kensa would require a copy of the buildings SAP or heat loss report to provide a more accurate sizing before ordering.